

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-1157:111 Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Digital Monitoring Products, \*2500 N. Partnership Blvd., Springfield, MO 65803  
Contact: Terry Shelton (417) 831-9362 FAX (417) 831-1325

**DESIGN:** Model 802 multi-tone audible devices. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Model 802 is surface mount and suitable for outdoor use with Model 843 back box.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as an audible signaling devices for use with separately listed electrically compatible fire alarm control units. Not suitable for the hearing impaired application.

This appliance can produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to listee's Installation Instructions Manual for details.

**XLF:** 7135-0785:118

\*Rev. 03-04-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager